



SOIL MAP LEGEND		NOTES
	SUITABLE	These soils are generally suitable for conventional absorption fields with proper design, installation and maintenance. Soil types observed within this map unit are similar to the Bethlehem, Cecil, Pacolet, and Madison Series. Minor inclusions of soils with perched water tables may occur within this mapping unit.
	MARGINAL	These soils are unsuitable for conventional absorption fields due to perched and seasonal high water table conditions. Soils are generally suitable for alternative absorption fields with treatment systems producing "Class 1 effluent". Based off the preliminary investigation, these soils do not exist on this property.
	UNSUITABLE	These soils are unsuitable for on-site wastewater disposal due to seasonal high water table, flooding, and/or storm water drainage patterns. Based off the preliminary investigation, these soils do not exist on this property.

NOTES:

- Survey or plat of the lot was not available. Plat represented in the drawing is not a survey. It is only an approximation of the lot dimensions. This drawing is for the purpose of showing the approximate location of soil sampling points within the project site and soil boundaries in relation to the sampling points.
- Topographic information and location of structures should be considered approximate.
- Terraces in the vicinity of absorption field construction should be graded out to improve surface water drainage.
- Soil boundary lines should be considered transitional zones between different soil conditions or series rather than an exact boundary.
- System installation should not occur under saturated or wet soil conditions
- Absorption fields should not be installed on concave slopes.
- Surface drainage should be diverted away from absorption field lines.
- Gutter downspouts should be discharged away from the vicinity of the on site wastewater system.
- Estimated percolation rates are based on full-sized system performance. However, no guarantee is given or implied as to the performance of any particular system installed.





MAP LEGEND	
	Soil Boundary
B1	Soil Boring
	Slope Direction
	Gully

GRAPHIC SCALE

50 0 50 100

(IN FEET)
1 inch = 100 ft.

AES
Applied Environmental Sciences, Inc.
8080 Wells Street, Suite 2C #45 Senoia, Georgia 30276
(678) 262-4020 (678) 262-4024 (fax) www.soilmapping.com

PRELIMINARY SOIL MAP
CUMMINGS RD
PN'S: C061-032 & C061-034
LAND LOT 113, 7th DISTRICT
CRAWFORD COUNTY, GEORGIA

DATE: 5-21-26	
SCALE: 1" = 100'	
CLIENT: JACOB BREAZEALE	
BORING LOCATION METHOD: TRIMBLE GEO 7X GPS	
FIELD WORK BY: JBS	
CHECKED BY: J. BRANDON STUART, DPH CSC, #438	